



DEPARTMENT OF THE AIR FORCE
366TH CIVIL ENGINEER SQUADRON (ACC)
MOUNTAIN HOME AIR FORCE BASE IDAHO

04 October 2024

MEMORANDUM FOR IDAHO DEPARTMENT OF ENVIRONMENTAL QUALITY

FROM: 366 CEIE/CES
1100 Liberator St.
MHAFB, ID 83648

SUBJECT: Lead Service Line Replacement Plan – Mountain Home Air Force Base, PWSID#
ID4200054

1. An inventory of all Service Lines was completed at Mountain Home AFB, ID, PWSID# ID4200054 from 30 October 2023 to 4 October 2024. This inventory was conducted using existing water system information, construction date of lines, visual inspection of lines, and interviews with the installation personnel to determine each service line classification per the EPA Lead and Copper Rule Revision. The Corps of Engineers – Omaha District, CENWO, utilized this information to provide the attached Inventory Spreadsheet, specific to Idaho, with a high level of confidence that the information is accurate.
2. The inventory of PWS ID4200054 identified a total of 1053 Service Lines within the system. All lines were identified as non-lead with material type listed within the spreadsheet. This was verified through service line material, construction date, replacement information, visual inspection, and interviews with the system primary contract.
3. Due to all lines being known as non-lead, there is no requirement for a Lead Service Line Replacement Plan (LSLRP) at Mountain Home AFB, ID.
4. Point of Contact for this memorandum is the undersigned at katie.gomez.1@us.af.mil.

KATIE L. GOMEZ, GS-12, DAF
MHAFB Water Quality Manager